

# CONFORMITY DECLARATION

According to UNI EN 1090-1:2009 + A1:2011



IIS Cert s.r.l. 0475 has performed the initial inspection or FPC surveillance according to 3a system and has issued the certificate of factory production control nr. 0475-CPR-166

## Performance declaration N: 01-22

**Passoni Paolo & Figli S.r.l.**

Address: **Via Aristotele, 23 – 20861 Brugherio (MB)**

**STATES, under its own responsibility**

That the construction named : **Stationary batteries racks**

## COMPLIES WITH

**the requirements of UNI EN 1090-1:2009 + A1:2011**

In compliance with the following specification of the component: **PPCS-1**

It also meets the the following requirements:

**Tolerance on geometric data:** EN 1090-2 appendix B

**Weldability:** EN 10025-2 S235JR

**Fracture toughness :** EN 10025-2 S235JR - Resilience  $\geq 27J$  to  $20C^{\circ}$

**Capacity of load support :** NPD

**Fatigue resistance :** NPD

**Fire resistant :** NPD

**Reaction to fire :** EN 13501-1 Classe E

**Realise of Cadmium:** NPD

**Realise of radioactivity :** NPD

**Durability** minimum 5 years if used according to the instructions defined

Structural features:

**Design:** NPD

**Manufacture:** According to the components specification PPCS-1 and the EN 1090-2, execution class EXC3

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation(EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Person empowered to draw up the declaration

Signature

Andrea Doi

Responsible FPC

Brugherio, 07/01/2022